



ADDENDUM #2

Date: June 21, 2021

To: All Bid Document Holders

City of Palmer – Wastewater Treatment Facility Improvements – Phase II

The following changes, additions, and/or deletions are hereby made a part of the Request for Bid as fully and completely as if same were fully set forth herein:

GENERAL

1. Attendance sheet for pre-bid conference/plan holders list attached to this addendum.
2. For the 24-ML line from the MBBR effluent to the secondary flow splitter; the invert at the existing 24" tee at the MBBR effluent is approximately 144'. Additional details on pipe lengths, inverts, etc. can be determined from the plans and sections in Volume 3_Drawings.

Signed by the Project Manager

A handwritten signature in blue ink, appearing to be "J. D. M.", is written over a horizontal line.

Dated 6/21/2021

