

February 29, 2024

TO: All Planholders of Record

RE: Addendum No. 2

Bid #24-01

Construct Bogard Road Booster Station

City of Palmer

This addendum consists of two (2) pages.

Bid Opening date and time remain unchanged.

Bidders must acknowledge the receipt of this addendum in writing on the Bid Proposal. This addendum amends and/or supplements the contract documents. Contract document provisions not specifically amended herein remain in full force and effect.

CLARIFICATIONS/EXPLANATIONS: In response to questions posed.

1. Q: PACO VL series vertical inline pumps are listed as the basis of design, but the specifications call for end suction, rear pull-out pumps. Is the intent to use end suction or vertical inline close coupled pumps?
A: See revisions to bidding and contract documents.
2. Q: The specifications call for a bronze impeller to be used on all Vertical inline pumps. Are stainless steel impellers acceptable if the pump has NSF 61 certification?
A: See revisions to bidding and contract documents.

BIDDING AND CONTRACT DOCUMENTS:

A. Modification to Part II Additional Project Specifications.

- 1) Specification Section 22 11 23 – Domestic Water Pumps:

Article 2.2 A: Delete Item 1 in its entirety and substitute the following:

The pumps shall be single stage vertical impeller design. The seal shall be serviceable without disturbing the piping connections. The capacities and characteristics shall be as called for in the plans/schedules.

Civil
Engineering

Geotechnical
Engineering

Transportation
Engineering

Aviation
Engineering

W/WW
Engineering

Environmental
Services

Surveying &
Mapping

Construction
Administration

Material
Testing

Article 2.2 A: Delete Item 5 in its entirety and substitute the following:

The impeller shall be ANSI 304/304L stainless steel and hydraulically balanced. The impeller shall be dynamically balanced to ANSI Grade G6.3 and shall be fitted to the shaft with a key.

- 2) Specification Section 26 05 00 Electrical Work, General:

Article 1.6 D: Add the following sentences:

Electrical service will not be immediately available. City of Palmer's submission and payment of the required Commercial Service Applications are expected by April 1, 2024.

END OF ADDENDUM NO. 2